

11 July 2018  
C/O: Spectrum Laboratories Ltd  
1/25 Highbrook Drive,  
East Tamaki,  
Auckland,  
New Zealand

Maker Studio Ltd

Dear Sir / Madam,

**APPROVAL OF PRESCRIBED EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.


Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the approval.

Should you have any queries, please contact Jean Marie Ntahnkiriye on telephone (03) 9203 9700, or email [jntahnkiriye@esv.vic.gov.au](mailto:jntahnkiriye@esv.vic.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change of registered Address within 20 business days.

Yours sincerely



**DIRECTOR OF ENERGY SAFETY**

Ref: ESV180338/00

Certificate Number: ESV180338/00

# Certificate of Approval

This is to certify that the Director of Energy Safety has approved the electrical equipment described hereunder.

**Registered Declarant:** Maker Studio Ltd  
652 Welcome Bay Road, Rd 5, Tauranga, 3175, New Zealand

## Required Marking: ESV180338

Electrical equipment covered by this approval must comply in all respects with the approved article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the required marking indicated above, or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

### ARTICLE DETAILS

Electrical Equipment:	Level 3 Luminaire - Portable Type Luminaire - Portable Type
Relevant Standards:	AS/NZS 60598.2.4:2005+A1 & AS/NZS 60598.1:2013
Expiry Date:	11 July 2023
Conditions of Approval:	Model ioFlr Luminaire without foot switch



Certificate Number: ESV180338/00



## Approval details

Model	ioFlr, ioTbl
Rated at	Input: 240 V~, 60 W max, 50 Hz
Trade Name	Maker Studio Ltd
Comments	

A handwritten signature in black ink, appearing to read "A. J. Flewson", is written over a light grey rectangular background.